



Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA


Website: <http://www.seabird.com>

Phone: (425) 643-9866

FAX: (425) 643-9954

Email: seabird@seabird.com*Field Season**2010**Primary***SBE Pressure Test Certificate**Test Date: 5/22/2008Description SBE-9Plus CTDJob Number: 47490Customer Name MD Marine Electric**SBE Sensor Information:**Model Number: 09Serial Number: 0906**Pressure Sensor Information:**Sensor Type: DigiQuartzSensor Serial Number: 107068Sensor Rating: 10000**Pressure Test Protocol:**Low Pressure Test: 40 PSI Held For 15 MinutesHigh Pressure Test: 10000 PSI Held For 15 MinutesPassed Test: ☒

Tested By: ND



CALIBRATION COEFFICIENTS

PAROSCIENTIFIC
PRESSURE TRANSDUCER

Corrected coefficients for SBE-9plus, SN 0906.

Serial No: **107068**
Original Cal Date: 9/11/2007
Corrected Cal Date: 6/9/2008

MODEL:	PRESSURE RANGE:	TEMP. RANGE:	PORT:
410K-134	0 to 10000 psia	0 to 125 deg C	oil filled

PRESSURE COEFFICIENTS

U = temperature (deg C)

T = pressure period (μsec)

$$C = C_1 + C_2U + C_3U^2$$

$$D = D_1 + D_2U$$

$$T_0 = T_1 + T_2U + T_3U^2 + T_4U^3 + T_5U^4$$

pressure: (psia)

$$P = C(1 - (T_0^2/T^2))(1 - D(1 - (T_0^2/T^2)))$$

<i>C1</i>	<i>-45806.14</i>	<i>psia</i>
<i>C2</i>	<i>-3.898443E-01</i>	<i>psia/deg C</i>
<i>C3</i>	<i>1.3305E-02</i>	<i>psia/deg C²</i>
<i>D1</i>	<i>0.032989</i>	
<i>D2</i>	<i>0</i>	
<i>T1</i>	<i>30.25149</i>	<i>μsec</i>
<i>T2</i>	<i>-4.453719E-04</i>	<i>μsec/deg C</i>
<i>T3</i>	<i>3.33012E-06</i>	<i>μsec /deg C²</i>
<i>T4</i>	<i>6.10635E-09</i>	<i>μsec /deg C³</i>
<i>T5</i>	<i>0</i>	



Digiquartz Pressure Calibration Coefficients

Corrected at Sea-Bird Electronics on **09-Jun-2008**
as per Paroscientific Calibration and SBE dP/dT tests.

(Changed coefficients are posted in italics.)

CALIBRATION COEFFICIENTS

SERIAL NO : 107068

PRESSURE TRANSDUCER

DATE : 09-11-2007

MODEL :	PRESSURE RANGE :	TEMP. RANGE :	PORT :
410K-134	0 to 10000 psia	0 to 125 deg C	oil filled

PRESSURE COEFFICIENTS

U = temperature
(deg C)

$$C = C_1 + C_2U + C_3U^2$$

$$D = D_1 + D_2U$$

$$T_0 = T_1 + T_2U + T_3U^2 + T_4U^3 + T_5U^4$$

T = pressure period
(μsec)

Pressure : (psia)

$$P = C \left(1 - \frac{T_0^2}{T^2}\right) \left(1 - D \left(1 - \frac{T_0^2}{T^2}\right)\right)$$

C ₁	-45804.11 psia
C ₂	-3.49118E-01 psia/deg C
C ₃	1.33045E-02 psia/deg C ²

D ₁	0.032989
D ₂	0

T ₁	30.25212 μsec
T ₂	-4.32828E-04 μsec/deg C
T ₃	3.33012E-06 μsec/deg C ²
T ₄	6.10635E-09 μsec/deg C ³
T ₅	0

(09-11-2007)

HISTORY

PAROSCIENTIFIC, INC.

4500 148th AVENUE N.E.
REDMOND, WA. 98052

CUSTOMER : SEABIRD ELECTRONICS, INC.



SALES ORDER : 24499

PREPARED BY : T.C.

CALIBRATION COEFFICIENTS

SERIAL NO : 107068

PRESSURE TRANSDUCER

DATE : 09-11-2007

MODEL :	PRESSURE RANGE :	TEMP. RANGE :	PORT :
410K-134	0 to 10000 psia	0 to 125 deg C	oil filled

PRESSURE COEFFICIENTS AT FIXED TEMPERATURE

(only valid at specified temperature)

T = pressure period (μ sec)

Pressure equation : (psia)

$$P = C \left(1 - \frac{T_0^2}{T^2} \right) \left(1 - D \left(1 - \frac{T_0^2}{T^2} \right) \right)$$

Temperature: 21.0 C

C (psia)	-45805.58				
D	0.032989				
T ₀ (μ sec)	30.24455				

(09-11-2007)

PAROSCIENTIFIC, INC.4500 148th AVENUE N.E.
REDMOND, WA. 98052

CUSTOMER : SEABIRD ELECTRONICS, INC.



SALES ORDER : 24499

PREPARED BY : T.C.

primary

SEA-BIRD ELECTRONICS, INC.

1808 136th Place N.E., Bellevue, Washington, 98005 USA

Phone: (425) 643 - 9866 Fax (425) 643 - 9954 Email: seabird@seabird.com

SENSOR SERIAL NUMBER: 5023
CALIBRATION DATE: 29-May-08SBE3 TEMPERATURE CALIBRATION DATA
ITS-90 TEMPERATURE SCALE

ITS-90 COEFFICIENTS

$g = 4.39259975e-003$
 $h = 6.39056784e-004$
 $i = 2.21710408e-005$
 $j = 2.04065077e-006$
 $f_0 = 1000.0$

IPTS-68 COEFFICIENTS

$a = 3.68121248e-003$
 $b = 5.96167618e-004$
 $c = 1.51299775e-005$
 $d = 2.04208808e-006$
 $f_0 = 3172.501$

BATH TEMP (ITS-90)	INSTRUMENT FREQ (Hz)	INST TEMP (ITS-90)	RESIDUAL (ITS-90)
-1.5000	3172.501	-1.5000	-0.00001
1.0000	3356.581	1.0000	0.00001
4.5000	3627.111	4.5000	0.00003
8.0000	3912.978	8.0000	-0.00003
11.5000	4214.614	11.5000	-0.00000
15.0000	4532.417	15.0000	0.00001
18.5000	4866.783	18.5000	0.00001
22.0000	5218.093	22.0000	-0.00001
25.5000	5586.722	25.5000	0.00001
29.0000	5973.018	29.0000	0.00001
32.5000	6377.322	32.5000	-0.00001

Temperature ITS-90 = $1/\{g + h[\ln(f_0/f)] + i[\ln^2(f_0/f)] + j[\ln^3(f_0/f)]\} - 273.15$ (°C)


Temperature IPTS-68 = $1/\{a + b[\ln(f_0/f)] + c[\ln^2(f_0/f)] + d[\ln^3(f_0/f)]\} - 273.15$ (°C)

Following the recommendation of JPOTS: T_{68} is assumed to be $1.00024 * T_{90}$ (-2 to 35 °C)

Residual = instrument temperature - bath temperature

Date, Offset(mdeg C)

29-May-08 -0.00





Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA

Website: <http://www.seabird.com>

Phone: (425) 643-9866

FAX: (425) 643-9954

Email: seabird@seabird.com

SBE Pressure Test Certificate

Test Date: 10/12/2007 Description SBE-3 Temperature Sensor

Job Number: 47490 Customer Name MD Marine Electric

SBE Sensor Information:

Model Number: 03

Serial Number: 5023

Pressure Sensor Information:

Sensor Type: None

Sensor Serial Number: None

Sensor Rating: 0


Pressure Test Protocol:

Low Pressure Test: 40 PSI Held For 15 Minutes

High Pressure Test: 10000 PSI Held For 15 Minutes

Passed Test: ☒

Tested By: FS



Secondary

SEA-BIRD ELECTRONICS, INC.

1808 136th Place N.E., Bellevue, Washington, 98005 USA

Phone: (425) 643 - 9866 Fax (425) 643 - 9954 Email: seabird@seabird.com

SENSOR SERIAL NUMBER: 5026
CALIBRATION DATE: 29-May-08SBE3 TEMPERATURE CALIBRATION DATA
ITS-90 TEMPERATURE SCALE

ITS-90 COEFFICIENTS

$g = 4.33081673e-003$
 $h = 6.33607551e-004$
 $i = 2.08477308e-005$
 $j = 1.82929335e-006$
 $f_0 = 1000.0$

IPTS-68 COEFFICIENTS

$a = 3.68121212e-003$
 $b = 5.95759866e-004$
 $c = 1.50644779e-005$
 $d = 1.83069634e-006$
 $f_0 = 2882.648$

BATH TEMP (ITS-90)	INSTRUMENT FREQ (Hz)	INST TEMP (ITS-90)	RESIDUAL (ITS-90)
-1.5000	2882.648	-1.5000	0.00001
1.0000	3050.023	1.0000	-0.00002
4.5000	3296.019	4.5000	-0.00000
8.0000	3555.981	8.0000	-0.00002
11.5000	3830.302	11.5000	0.00004
15.0000	4119.347	15.0000	0.00002
18.5000	4423.485	18.5000	-0.00002
22.0000	4743.073	22.0000	-0.00005
25.5000	5078.463	25.5000	0.00002
29.0000	5429.972	29.0000	0.00003
32.5000	5797.919	32.5000	-0.00001

$$\text{Temperature ITS-90} = 1 / \{ g + h[\ln(f_0/f)] + i[\ln^2(f_0/f)] + j[\ln^3(f_0/f)] \} - 273.15 \text{ (}^\circ\text{C)}$$


$$\text{Temperature IPTS-68} = 1 / \{ a + b[\ln(f_0/f)] + c[\ln^2(f_0/f)] + d[\ln^3(f_0/f)] \} - 273.15 \text{ (}^\circ\text{C)}$$

Following the recommendation of JPOTS: T_{68} is assumed to be $1.00024 * T_{90}$ (-2 to 35 $^\circ\text{C}$)

Residual = instrument temperature - bath temperature

Date, Offset(mdeg C)

29-May-08 0.00





Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA
Website: <http://www.seabird.com>

Phone: (425) 643-9866
FAX: (425) 643-9954
Email: seabird@seabird.com

SBE Pressure Test Certificate

Test Date: 10/12/2007 Description SBE-3 Temperature Sensor

Job Number: 47490 Customer Name MD Marine Electric

SBE Sensor Information:

Model Number: 03
Serial Number: 5026

Pressure Sensor Information:

Sensor Type: None
Sensor Serial Number: None
Sensor Rating: 0


Pressure Test Protocol:

Low Pressure Test: 40 PSI Held For 15 Minutes

High Pressure Test: 10000 PSI Held For 15 Minutes

Passed Test: ☒

Tested By: FS



primary

SEA-BIRD ELECTRONICS, INC.

1808 136th Place N.E., Bellevue, Washington, 98005 USA

Phone: (425) 643 - 9866 Fax (425) 643 - 9954 Email: seabird@seabird.com

SENSOR SERIAL NUMBER: 3455
CALIBRATION DATE: 03-Jun-08SBE4 CONDUCTIVITY CALIBRATION DATA
PSS 1978: C(35,15,0) = 4.2914 Siemens/meter**GHIJ COEFFICIENTS**

$g = -1.00952036e+001$
 $h = 1.56202306e+000$
 $i = -2.33201013e-003$
 $j = 2.64582197e-004$
 $CPcor = -9.5700e-008$ (nominal)
 $CTcor = 3.2500e-006$ (nominal)

ABCDM COEFFICIENTS

$a = 4.58306124e-007$
 $b = 1.55598008e+000$
 $c = -1.00835243e+001$
 $d = -8.54917697e-005$
 $m = 6.4$
 $CPcor = -9.5700e-008$ (nominal)


BATH TEMP (ITS-90)	BATH SAL (PSU)	BATH COND (Siemens/m)	INST FREQ (kHz)	INST COND (Siemens/m)	RESIDUAL (Siemens/m)
0.0000	0.0000	0.00000	2.54567	0.00000	0.00000
-1.0000	34.9177	2.81198	4.95423	2.81196	-0.00002
1.0000	34.9177	2.98380	5.06436	2.98383	0.00002
15.0000	34.9182	4.28279	5.82947	4.28280	0.00001
18.5000	34.9174	4.63033	6.01755	4.63031	-0.00002
32.5000	34.9126	6.09088	6.75041	6.09088	0.00000

$$\text{Conductivity} = (g + hf^2 + if^3 + jf^4) / 10(1 + \delta t + \epsilon p) \text{ Siemens/meter}$$

$$\text{Conductivity} = (af^m + bf^2 + c + dt) / [10(1 + \epsilon p)] \text{ Siemens/meter}$$
 $t = \text{temperature}[^{\circ}\text{C}]; p = \text{pressure}[\text{decibars}]; \delta = CTcor; \epsilon = CPcor;$
 $\text{Residual} = (\text{instrument conductivity} - \text{bath conductivity}) \text{ using } g, h, i, j \text{ coefficients}$

Date, Slope Correction

03-Jun-08 1.0000000





Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA
Website: <http://www.seabird.com>

Phone: (425) 643-9866
FAX: (425) 643-9954
Email: seabird@seabird.com

SBE Pressure Test Certificate

Test Date: 6/25/2007

Description SBE-4 Conductivity Sensor

Job Number: 47490

Customer Name MD Marine Electric

SBE Sensor Information:

Model Number: 04

Serial Number: 3455

Pressure Sensor Information:

Sensor Type: None

Sensor Serial Number: None

Sensor Rating: 0


Pressure Test Protocol:

Low Pressure Test: 40 PSI Held For 15 Minutes

High Pressure Test: 10000 PSI Held For 15 Minutes

Passed Test: ☒

Tested By: FS



SEA-BIRD ELECTRONICS, INC.

1808 136th Place N.E., Bellevue, Washington, 98005 USA

Phone: (425) 643 - 9866 Fax (425) 643 - 9954 Email: seabird@seabird.com

SENSOR SERIAL NUMBER: 3456
CALIBRATION DATE: 03-Jun-08SBE4 CONDUCTIVITY CALIBRATION DATA
PSS 1978: C(35,15,0) = 4.2914 Seimens/meter**GHIJ COEFFICIENTS**

$g = -9.95398347e+000$
 $h = 1.51635985e+000$
 $i = -2.16218587e-003$
 $j = 2.50397387e-004$
 $CPcor = -9.5700e-008$ (nominal)
 $CTcor = 3.2500e-006$ (nominal)

ABCDM COEFFICIENTS

$a = 6.81351244e-007$
 $b = 1.51081274e+000$
 $c = -9.94337606e+000$
 $d = -8.71621609e-005$
 $m = 6.2$
 $CPcor = -9.5700e-008$ (nominal)

BATH TEMP (ITS-90)	BATH SAL (PSU)	BATH COND (Siemens/m)	INST FREQ (kHz)	INST COND (Siemens/m)	RESIDUAL (Siemens/m)
0.0000	0.0000	0.00000	2.56541	0.00000	0.00000
-1.0000	34.9177	2.81198	5.01836	2.81196	-0.00002
1.0000	34.9177	2.98380	5.13032	2.98383	0.00002
15.0000	34.9182	4.28279	5.90784	4.28280	0.00002
18.5000	34.9174	4.63033	6.09893	4.63031	-0.00002
32.5000	34.9126	6.09088	6.84333	6.09088	0.00000

$$\text{Conductivity} = (g + hf^2 + if^3 + jf^4) / 10(1 + \delta t + \epsilon p) \text{ Siemens/meter}$$


$$\text{Conductivity} = (af^m + bf^2 + c + dt) / [10(1 + \epsilon p)] \text{ Siemens/meter}$$

$$t = \text{temperature}[^{\circ}\text{C}]; p = \text{pressure}[\text{decibars}]; \delta = CTcor; \epsilon = CPcor;$$

$$\text{Residual} = (\text{instrument conductivity} - \text{bath conductivity}) \text{ using } g, h, i, j \text{ coefficients}$$

Date, Slope Correction

03-Jun-08 1.0000000





Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA

Website: <http://www.seabird.com>

Phone: (425) 643-9866

FAX: (425) 643-9954

Email: seabird@seabird.com

SBE Pressure Test Certificate

Test Date: 6/25/2007 Description SBE-4 Conductivity Sensor

Job Number: 47490 Customer Name MD Marine Electric

SBE Sensor Information:

Model Number: 04

Serial Number: 3456

Pressure Sensor Information:

Sensor Type: None

Sensor Serial Number: None

Sensor Rating: 0


Pressure Test Protocol:

Low Pressure Test: 40 PSI Held For 15 Minutes

High Pressure Test: 10000 PSI Held For 15 Minutes

Passed Test: ☒

Tested By: FS





Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA

Website: <http://www.seabird.com>

Tel: (425) 643-9866

Email: seabird@seabird.com

Fax: (425) 643-9866

SBE 5T SUBMERSIBLE PUMP CONFIGURATION SHEET

Customer: **MD Marine Electric**

Delivery Date: **5/20/2008**

Serial Number: **4974**

MRP PN: **90543**

Job Number: **47490**

Pressure Case: 10,500 meters (titanium)

Pittman Motor Type:

P/N 3711B113-R1, 18.02 ohms nominal (For applications up to 2000 RPM MAX) ☐

5 Winding, low voltage input (jump P5 to P7)
(80676 assy/3711B113-R1 motor) ☐

5 Winding, standard voltage input (jump P5 to P6)
(80676 assy/3711B113-R1 motor) ☐

P/N 3711B112-R1, 7.40 ohms nominal (For applications up to 4500 RPM MAX) ☐

3 Winding, low voltage input (jump P5 to P7)
(80675 assy/3711B112-R1 motor) ☐

3 Winding, standard voltage input (jump P5 to P6)
(80675 assy/3711B112-R1 motor) ☐

P/N 3711B112-R2, 3.55 ohms nominal (For applications up to 4500 RPM MAX) ☒

3 Winding, low voltage input (jump P5 to P7)
(801572 assy/3711B112-R2 motor) ☐

3 Winding, standard voltage input (jump P5 to P6)
(801572 assy/3711B112-R2 motor) ☒

Speed Adjust Range: Min: **930** RPM Max: **5010** RPM (@ 12 Vin/300mA load)

Final Speed Setting: **3000** RPM (TP1 = **100.0** Hz)

Low voltage pumps only:

Motor speed at 7.5 Vin with no load: **0** RPM (TP1 = **0.0** Hz)

Motor speed at 7.5 Vin with 200mA load: **0** RPM (TP1 = **0.0** Hz)

Motor dropout voltage: **9.3**



Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA

Website: <http://www.seabird.com>

Phone: (425) 643-9866

FAX: (425) 643-9954

Email: seabird@seabird.com

SBE Pressure Test Certificate

Test Date: 5/12/2008 Description SBE-5T Submersible Pump

Job Number: 47490 Customer Name MD Marine Electric

SBE Sensor Information:

Model Number: 5T

Serial Number: 4974

Pressure Sensor Information:

Sensor Type: None

Sensor Serial Number: None

Sensor Rating: 0


Pressure Test Protocol:

Low Pressure Test: 40 PSI Held For 15 Minutes

High Pressure Test: 10000 PSI Held For 15 Minutes

Passed Test: ☒

Tested By: FS




Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA

 Website: <http://www.seabird.com>
Secondary

Tel: (425) 643-9866

 Email: seabird@seabird.com

Fax: (425) 643-9866

SBE 5T SUBMERSIBLE PUMP CONFIGURATION SHEET

 Customer: **MD Marine Electric**

 Delivery Date: **5/20/2008**

 Serial Number: **4975**

 MRP PN: **90543**

 Job Number: **47490**

Pressure Case: 10,500 meters (titanium)

Pittman Motor Type:
P/N 3711B113-R1, 18.02 ohms nominal (For applications up to 2000 RPM MAX)

 5 Winding, low voltage input (jump P5 to P7)
 (80676 assy/3711B113-R1 motor)

 5 Winding, standard voltage input (jump P5 to P6)
 (80676 assy/3711B113-R1 motor)

P/N 3711B112-R1, 7.40 ohms nominal (For applications up to 4500 RPM MAX)

 3 Winding, low voltage input (jump P5 to P7)
 (80675 assy/3711B112-R1 motor)

 3 Winding, standard voltage input (jump P5 to P6)
 (80675 assy/3711B112-R1 motor)

P/N 3711B112-R2, 3.55 ohms nominal (For applications up to 4500 RPM MAX)

 3 Winding, low voltage input (jump P5 to P7)
 (801572 assy/3711B112-R2 motor)

 3 Winding, standard voltage input (jump P5 to P6)
 (801572 assy/3711B112-R2 motor)

 Speed Adjust Range: Min: **930** RPM Max: **5220** RPM (@ 12 Vin/300mA load)

 Final Speed Setting: **3000** RPM (TP1 = **100.0** Hz)

Low voltage pumps only:

 Motor speed at 7.5 Vin with no load: **0** RPM (TP1 = **0.0** Hz)

 Motor speed at 7.5 Vin with 200mA load: **0** RPM (TP1 = **0.0** Hz)

 Motor dropout voltage: **9.3**



Sea-Bird Electronics, Inc.

1808 136th Place NE, Bellevue, Washington 98005 USA

Website: <http://www.seabird.com>

Phone: (425) 643-9866

FAX: (425) 643-9954

Email: seabird@seabird.com

SBE Pressure Test Certificate

Test Date: 5/12/2008

Description SBE-5T Submersible Pump

Job Number: 47490

Customer Name MD Marine Electric

SBE Sensor Information:

Model Number: 5T

Serial Number: 4975

Pressure Sensor Information:

Sensor Type: None

Sensor Serial Number: None

Sensor Rating: 0

Pressure Test Protocol:

Low Pressure Test: 40 PSI Held For 15 Minutes

High Pressure Test: 10000 PSI Held For 15 Minutes

Passed Test: ☒

Tested By: FS

